

September 3, 2019



Survey For Asbestos Containing Materials

Vacant Single-Family Residence
762 Schoharie Hill Road
Schoharie, New York 12157

Prepared for:

GREATER MOHAWK VALLEY LAND BANK
500 E. Main Street, Suite 2A
Little Falls, New York 13365



Prepared by:

HSE CONSULTING SERVICES, LLC
3216 Watson Boulevard
Endwell, New York 13760
(888) 419-1438
FAX (315) 698-1441
www.hseconsultingservices.com

© Copyright 2019
HSE Consulting Services, LLC

Table of Contents

1.0	PROJECT PERSONNEL.....	1
2.0	INTRODUCTION.....	2
3.0	BACKGROUND INFORMATION	2
3.1	Health Effects	2
3.2	Federal and State Asbestos Regulation Summary	3
3.3	US Occupational Safety and Health Administration (OSHA)	3
3.4	US Environmental Protection Agency (EPA)	4
3.5	New York State Department of Labor (DOL).....	5
4.0	METHODOLOGY	5
4.1	Friable Sample Analysis.....	5
4.2	Non-friable Organically Bound (NOB) Sample Analysis	5
5.0	DISCUSSION	6
6.0	CONCLUSIONS / RECOMMENDATIONS	7

APPENDIX 1

Site Location Map

APPENDIX 2

Project Diagrams

APPENDIX 3

Project Photos

APPENDIX 4

Homogenous Area Listing

APPENDIX 5

Firm NYSDOL Asbestos Handling License

APPENDIX 6

NYSDOL Asbestos Inspector Certificate

APPENDIX 7

Laboratory Analysis Reports & Chain-of-Custody Records

APPENDIX 8

NYSDOH ELAP Certificates of Approval



1.0 PROJECT PERSONNEL

<u>NAME</u>	<u>TITLE</u>	<u>AFFILIATION</u>
John Mazzarella III	Project Manager	Greater Mohawk Valley Land Bank
Chad C. Gable	Technical Services Manager/ Asbestos Inspector	HSE Consulting Services, LLC
Daniel R. Hoosock	Asbestos Inspector/ Vice President	HSE Consulting Services, LLC
Douglas Gee	Asbestos Analyst	HSE Consulting Services, LLC
Michael Norman	Asbestos Analyst	HSE Consulting Services, LLC
Brian C. King, CIH	President	HSE Consulting Services, LLC

2.0 INTRODUCTION

In accordance with a request made by Mr. John Mazzarella, Project Manager for the Greater Mohawk Valley Land Bank (GMVLB), HSE Consulting Services, LLC (HSE) has completed an asbestos survey for the vacant single family residence located at 762 Schoharie Hill Road in the Town of Schoharie, Schoharie County, New York 12157. The following information related to the property and structure was obtained from the Schoharie County web site, or during site inspection activities:



Tax Map Number	⇒	70.-3-7
Property Class	⇒	210 – 1 Family Residence
Stories	⇒	2
Year Built	⇒	1860
Square Feet	⇒	± 1,734
Basement	⇒	Full

A Site Location Map depicting the location of the property within the Town of Schoharie is included as Appendix 1 of this report. Project diagrams illustrating the layout of the structure are provided in Appendix 2 and representative photographs taken during site inspection activities are provided in Appendix 3.

The asbestos survey was conducted for the purpose of identifying asbestos containing materials (ACM's) that may be associated with the interior or exterior of the subject structure. Chad C. Gable and Daniel R. Hoosock of HSE, New York State Department of Labor (NYSDOL) certified Asbestos Building Inspectors, performed the asbestos survey on August 20, 2019 in general conformance with the requirements of Part 56 of Title 12 of the Official Compilation of Codes, Rules and Regulations of the State of New York (commonly cited as Code Rule 56).

3.0 BACKGROUND INFORMATION

3.1 Health Effects

Asbestos, a naturally occurring fibrous mineral silicate, was used extensively in building products from the early 1900's to the late 1970's. Asbestos was primarily used for thermal and acoustical insulation, fireproofing and decorative purposes. When these materials deteriorate or are disturbed, they may release microscopic fibers into the air where humans may readily inhale them. Once airborne, the fibers may remain suspended for extended periods due to their small size and aerodynamic shape.

Extensive medical evidence has shown that the inhalation of asbestos can cause asbestosis, lung cancer, pleural and peritoneal mesothelioma (cancer of the lining of the lungs and stomach, respectively) and gastrointestinal cancer. These diseases have a latency period of between ten (10) and forty (40) years and are usually fatal. The risk of disease is directly related to the amount of exposure (each exposure accumulates in the body). This is referred to as a dose-response relationship. Presently, medical models rely on the data gained from patients exposed to high occupational levels of asbestos fiber.

3.2 Federal and State Asbestos Regulation Summary

Governmental authorities on both the state and federal level have promulgated asbestos regulations. The US Occupational Safety and Health Administration and the US Environmental Protection Agency are the major regulators on the federal level.

3.3 US Occupational Safety and Health Administration (OSHA)

OSHA has established regulations for general industry (see title 29 of the Code of Federal Regulations (CFR) Part 1910, section 1001 (cited as 29 CFR 1910.1001)) and the construction industry (29 CFR 1926.1101). Separate standards for general industry and the construction industry, including demolition and renovation projects, were developed in recognition of the inherent differences between the industries. Both standards, which became effective in October of 1994 and required full compliance by February of 1995, may be applicable at a given time depending on the activities being conducted. These standards, which are primarily concerned with occupational exposures to asbestos, have established a permissible exposure limit (PEL) of 0.1 fibers per cubic centimeter of air (f/cc) based on an eight-hour time weighted average (TWA). An excursion limit of 1 f/cc for a thirty (30) minute TWA was also established. The general industry standard also mandates exposure monitoring and employee observation, the establishment of regulated areas, methods of compliance, respiratory protection, protective work clothing and equipment, hygiene facilities and practices, hazard communication, housekeeping practices, medical surveillance and recordkeeping.

The construction industry standard applies to all employees performing work for construction, alteration, and/or repair including painting and decorating regardless of place of employment. More specifically, the standard regulates asbestos exposure including but not limited to the following work:

- Demolition or salvage of structures where asbestos is present.
- Removal or encapsulation of materials containing asbestos.
- Construction, alteration, repair, maintenance, or renovation of structures, substrates, or portions thereof, which contain asbestos.
- Installation of products containing asbestos.
- Asbestos spill/emergency cleanup.
- Transportation, disposal, storage, containment and housekeeping activities involving asbestos or products containing asbestos, on the site or location at which construction activities are performed.

The construction standard also specifies requirements for multi-employer work sites, regulated areas, exposure assessments and monitoring, methods of compliance, respiratory protection, protective clothing, hygiene facilities and employee practices, communication of hazards, housekeeping, medical surveillance, recordkeeping and competent persons.

3.4 US Environmental Protection Agency (EPA)

The EPA primarily regulates atmospheric asbestos emissions and asbestos in schools (see 40 CFR Part 61 - Subpart M and 40 CFR Part 763 – Subpart E, respectively). The EPA’s National Emission Standards for Hazardous Air Pollutants (NESHAPS) Asbestos Regulations (40 CFR Part 61, Subpart M) must also be considered. These regulations:

- Require facility inspections.
- Define regulated asbestos-containing material as follows: Regulated asbestos-containing material (RACM) means (a) Friable asbestos material, (b) Category I non-friable ACM that has become friable, (c) Category I non-friable ACM that will be or has been subjected to sanding, grinding, cutting, or abrading, or (d) Category II non-friable ACM that has a high probability of becoming or has become crumbled, pulverized, or reduced to powder by the forces expected to act on the material in the course of demolition or renovation operations.

Note: Friable asbestos material means any material containing more than 1 percent asbestos that, when dry, can be crumbled, pulverized, or reduced to powder by hand pressure. Category I non-friable ACM means asbestos-containing packing, gaskets, resilient floor covering, and asphalt roofing products containing more than 1 percent asbestos. Category II non-friable ACM means any material, excluding Category I non-friable ACM, containing more than 1 percent asbestos that, when dry, cannot be crumbled, pulverized, or reduced to powder by hand pressure.

- Specify methods for controlling fiber release during renovation and demolition projects.
- Require personnel training.
- Delineate methods of transportation and disposal for ACM/PACM including “cradle to grave” manifesting.
- Include notification requirements. (i.e. The EPA’s regional office must be notified in writing if the combined amount of RACM to be stripped, removed, dislodged, cut, drilled, or similarly disturbed is at least 80 linear meters (260 linear feet) on pipes or at least 15 square meters (160 square feet) on other facility components, or at least 1 cubic meter (35 cubic feet) off facility components where the length or area could not be measured previously.

40 CFR Part 763 – Subpart E (the Asbestos-Containing Materials In Schools Rule), which was promulgated under the Asbestos Hazard Emergency Response Act (AHERA), is important in that the OSHA regulations incorporate requirements for training of employee’s, air monitoring protocols for certain activities, conducting building surveys, and bulk sampling of ACM. Also, the EPA NESHAPS for asbestos incorporates analytical techniques described in these regulations. Additionally, the New York State Department of Labor’s (NYSDOL) asbestos regulations incorporate the training requirements contained in these regulations.

It should also be noted that the US Department of Transportation (DOT – see 49 CFR parts 171 and 172) regulates the transportation of asbestos- containing waste material and requires waste containment and shipping papers.

3.5 New York State Department of Labor (DOL)

The New York State Department of Labor's (NYSDOL) asbestos regulations (see Part 56 of Title 12 NYCRR – commonly referred to as Code Rule 56) are designed to protect the public from asbestos exposures. They require training of persons employed to design, implement or inspect asbestos projects and those who supervise or employ them, certification of individuals involved in asbestos projects and licensing of asbestos abatement contractors. Standard work practices, materials and equipment, air monitoring, engineering controls, building surveys, record keeping, and compliance/enforcement criteria have also been established. NYSDOL notification is required before the initiation of large asbestos projects. The regulations designate projects that disturb amounts of ACM equal to or exceeding 160 square feet or 260 linear feet as large asbestos abatement projects. Projects involving the disturbance of between 10 square feet and 160 square feet or between 25 linear feet and 260 linear feet of ACM are designated as small asbestos abatement projects. Projects involving 10 square feet or less or 25 linear feet or less of ACM are designated as minor asbestos abatement projects. The level of regulation is adjusted progressively with each project designation.

It should be noted that the NYS Department of Health (DOH) has also promulgated regulations with respect to asbestos-containing material. The DOH accredits asbestos safety training programs, licenses analytical laboratories and monitors the quality of these endeavors.

4.0 METHODOLOGY

A thorough visual inspection was conducted to identify materials with the potential to contain asbestos. Bulk samples of identified suspect materials were then collected from representative locations in general conformance with Part 56 of Title 12 of the Official Compilation of Codes, Rules and Regulations of the State of New York (Cited as 12 NYCRR Part 56). The samples were transported with chain-of-custody documentation to HSE's laboratory in Cicero, New York for analysis. Samples with multiple layers were separated in either the field or the laboratory, if possible, and the layers were analyzed individually. The New York State Department of Health's (NYSDOH) has accredited HSE's asbestos laboratory under the Department's Environmental Laboratory Approval Program (ELAP).

4.1 Friable Sample Analysis

Friable and non-friable bulk samples were analyzed for asbestos content using Polarized Light Microscopy and Dispersion Staining techniques (PLM/DS) in accordance with New York State Department of Health (NYSDOH) Method 198.1. Laboratory results are reported as percent asbestos including an estimate of the amount of each type of asbestos present (e.g. chrysotile, Amosite, Crocidolite, Actinolite, Anthophyllite). The types and percentages of other non-asbestos fibers identified during the analytical procedure are also reported when feasible.

4.2 Non-friable Organically Bound (NOB) Sample Analysis

Non-Friable Organically Bound (NOB) materials, and ceiling tiles containing cellulose, were analyzed in accordance with NYSDOH Methods 198.6 and 198.4. Samples were first prepared by Gravimetric Matrix Reduction (GMR) and analyzed using Polarized Light Microscopy (PLM). If the

GMR/PLM procedure did not indicate an asbestos concentration of greater than one percent (1%), the corresponding samples were submitted for Transmission Electron Microscopy (TEM) analysis. NYSDOH-ELAP requirements mandate that before NOB materials can be considered or treated as non-asbestos containing, confirmation by the quantitative TEM analytical procedure is required.

5.0 DISCUSSION

A total of fifty-nine (59) bulk samples were collected as part of the completed asbestos survey (HSE Sample ID's CG82019-1 through CG82019-59). A total of seventeen (17) PLM analyses, forty-eight (48) NOB analyses and forty-four (44) TEM analyses were performed. Copies of the laboratory analysis reports and chain-of-custody records for samples collected as part of the completed survey are included in Appendix 7 of this report.

Current New York State Department of Labor (NYSDOL) and United States Environmental Protection Agency (USEPA) regulations define materials which contain greater than one percent (> 1 %) asbestos to be regulated ACM. Based on the results of the laboratory analyses performed for samples collected as part of the completed asbestos survey, as summarized in Table 1 below, none of the materials sampled and analyzed as part of the survey were determined to be ACM.

TABLE 1
Summary of Identified Asbestos-Containing Materials
762 Schoharie Hill Road, Schoharie NY

MATERIAL	LOCATION(S) ⁽⁵⁾	QTY ⁽²⁾ (ft ² or lf) ⁽¹⁾	FRIABILITY ⁽³⁾ (F, NF, NOB)	CONDITION
FIRST FLOOR				
Sink Coating	Area 102	8 ft ²	NOB	Fair
Ceiling Texture Coat	Area 103 and 105	461 ft ²	F	Fair
Wood Paneling Mastic	Area 103 and 105	696 ft ²	NOB	Fair
SECOND FLOOR				
No Asbestos Containing Materials Identified	N/A	N/A	N/A	N/A
ATTIC				
Loose-Fill Vermiculite ⁽⁴⁾	Attic Space Above Area 206	170 ft ²	F	Poor
BASEMENT				
Duct Seam Tape	Area B1	6 lf	F	Fair
EXTERIOR				
No Asbestos Containing Materials Identified	N/A	N/A	N/A	N/A

NOTES

- 1) ft² = square feet, lf = linear feet, ft³ = cubic feet
- 2) Dimensions and quantities, if applicable, are estimates. Abatement contractors shall verify actual material quantities.
- 3) F = Friable, NF = Non-friable, NOB = Non-friable organically bound
- 4) Residual loose-fill vermiculite insulation was observed in the attic space above Area 206 from an opening in the wall between Areas 206 and 207. An access point to attic space above Areas 201 through 205 could not be identified. It is possible that additional loose-fill vermiculite may be present within the attic space above those areas, or within wall and ceiling cavities. All loose-fill vermiculite must be handled and treated as ACM in accordance with applicable NYSDOH and NYSDOL requirements.
- 5) Refer to project diagrams in Appendix 2 for area locations

Materials Containing Less Than 1% Asbestos (i.e. Trace Asbestos)

Building materials identified to have trace amounts of asbestos based on the sampling and analyses performed as part of the completed survey are summarized below in Table 2.

TABLE 2

***Summary of Building Materials with Trace Asbestos Concentrations
Vacant Residential Structure, 762 Schoharie Hill Road, Schoharie, NY***

LOCATION	MATERIAL	FRIABILITY
Area 102	Black Backing/Mastic to Black 9" x 9" Floor Tile	NOB
Area 104	Black Backing to Multi-Color Floor Tile	NOB
Area 104	Mastic to Beige/Black 9" x 9" Floor Tile	NOB
Area 103	9x9 Wood Grain VCT Floor Tile	NOB
2 nd Floor Porch	White Rolled Roofing	NOB
Main Roof	Gray Shingle	NOB

NOTE: Materials with less than 1% asbestos are not considered to be ACM but some parts of the OSHA Construction Standard for Asbestos may apply (see 29 CFR 1926.1101 (g)(1) [except (g)(1)(i)], (g)(2) and (g)(3)).

6.0 CONCLUSIONS / RECOMMENDATIONS

Based on the results of the completed asbestos survey, the materials listed above in Table 1 were identified to be asbestos containing (see Section 5.0 and Appendices 2, 4 and 7). If additional suspect materials are uncovered during renovation or demolition activities that were not identified or assessed as part of this survey, activities which could disturb the suspect material must stop until the materials in question can be assessed (see Code Rule 56 Subpart 56-5.1(j)).



Subpart 56-5.1(g) also requires that one (1) copy of the results of the building/structure asbestos survey shall be immediately transmitted by the building/structure owner as follows:

- 1) One copy of the completed asbestos survey shall be sent by the owner or their agent to the local government entity charged with issuing a permit for such demolition, renovation, remodeling or repair work under applicable State or local laws.
- 2) The completed asbestos survey for controlled demolition (as per Subpart 56-11.5) or pre-demolition asbestos projects shall also be submitted to the appropriate Asbestos Control Bureau district office.
- 3) The completed asbestos survey for controlled demolition (as per Subpart 56-11.5) or pre-demolition asbestos projects shall also be submitted to the appropriate Asbestos Control Bureau district office.

The completed asbestos surveys shall be kept on the construction site with the asbestos notification and variance, if required, throughout the duration of the asbestos project and any associated demolition, renovation, remodeling or repair project

HSE appreciates the opportunity to provide asbestos survey services for this project to the GMVLB. Please do not hesitate to contact me at your convenience if you have any questions or require additional information regarding this report.

Respectfully Submitted By:
HSE CONSULTING SERVICES, LLC

A handwritten signature in black ink, appearing to read 'Chad C. Gable'.

Chad C. Gable
Technical Services Manager

S:\reports\ih\Greater Mohawk Valley Land Bank\762 Schoharie Hill Road\Asbestos Survey Report, 762 Schoharie Hill Rd., Schoharie, NY..docx




Appendix 1

Site Location Map

Site Location Map

Vacant Single-Family Residence
762 Schoharie Hill Road
Schoharie, New York 12157





Appendix 2

Project Diagrams




Figure Reference: Pre-Renovation Asbestos Survey



8636 Brewerton Road, Cicero, NY 13039
Telephone: 315-698-1438 ♦ Fax: 315-698-1441
www.hseconsultingservices.com

Figure 1 – First Floor Plan

Vacant Residential Structure
762 Schoharie Hill Road
Schoharie, New York 12157

KEY

↗ **CG82019-# =**
General Location
Of Positive (>1%)
Bulk Sample
(if applicable)

Drafter: Daniel R. Hoosock

Date: 9/3/2019

Project No.




Figure Reference: Pre-Renovation Asbestos Survey



8636 Brewerton Road, Cicero, NY 13039
Telephone: 315-698-1438 ♦ Fax: 315-698-1441
www.hseconsultingservices.com

Figure 2 – Second Floor Plan

Vacant Residential Structure
762 Schoharie Hill Road
Schoharie, New York 12157

Drafter: Daniel R. Hoosock

Date: 9/3/2019

Project No.

KEY

↗ **CG82019-# =**
General Location
Of Positive (>1%)
Bulk Sample
(if applicable)




Figure Reference: Pre-Renovation Asbestos Survey



8636 Brewerton Road, Cicero, NY 13039
Telephone: 315-698-1438 ♦ Fax: 315-698-1441
www.hseconsultingservices.com

Figure 3 – Basement Floor Plan

Vacant Residential Structure
762 Schoharie Hill Road
Schoharie, New York 12157


KEY

↗ **CG82019-# =**
General Location
Of Positive (>1%)
Bulk Sample
(if applicable)

Drafter: Daniel R. Hoosock

Date: 9/3/2019

Project No.



Project No.



Appendix 3

Representative Project Photos



PHOTO 1: Exterior of the structure generally looking northeast



PHOTO 2: Exterior of the structure generally looking northwest



PHOTO 3: Area 101



PHOTO 4: Area 102



PHOTO 5: Area 103



PHOTO 6: Area 104



PHOTO 7: Area 105



PHOTO 8: Area 201



PHOTO 9: Area 202



PHOTO 10: Area 203



PHOTO 11: Area 207



PHOTO 12: Basement



PHOTO 13: Asbestos containing seam tape insulation in basement



PHOTO 14: Asbestos containing seam tape insulation in basement




PHOTO 15: Asbestos containing ceiling texture coat in Areas 103 and 105



PHOTO 16: Residual loose-fill vermiculite in attic



Appendix 4

Homogenous Area Listing



ASBESTOS SURVEY
Homogenous Area Listing

Vacant Single-Family Residence
762 Schoharie Hill Road
Schoharie, New York 12157

HOMOGENOUS AREA (Material)	ACM Present? (> 1%)
Flower Pattern Linoleum	No
Square Pattern Linoleum	No
Sink Coating	Yes
Wall Paneling Mastic	No
Black 9x9 Floor Tile	No
Black Backing to Black 9x9 Floor Tile	No
Brown 9x9 Floor Tile w/Mastic	No
1x1 Ceiling Tile	No
Tub Caulk	No
Multi-Color Floor Tile w/Black Backing	No
9x9 Beige/Black VCT Floor Tile	No
Mastic to Beige/Black 9x9 Floor Tile	No

HOMOGENOUS AREA (Material)	ACM Present? (> 1%)
Multi-Color Pattern Linoleum	No
Ceramic Wall Tile Mastic	No
Duct Seam Tape	Yes
Ceiling Texture Coat	Yes
9x9 Wood Grain VCT Floor Tile	No
Black Backing to 9x9 Wood Grain Floor Tile	No
Wood Paneling Mastic	Yes
Plaster	No
Drywall	No
Joint Compound	No
Joint Tape	No
Window Glazing Compound	No



ASBESTOS SURVEY
Homogenous Area Listing

Vacant Single-Family Residence
762 Schoharie Hill Road
Schoharie, New York 12157

HOMOGENOUS AREA (Material)	ACM Present? (> 1%)
Brown Paper	No
White Rolled Roofing	No
Drywall (First Floor)	No
Gray Shingle	No
Tar Paper	No



Appendix 5

NYSDOL Firm Asbestos Handling License

New York State – Department of Labor

Division of Safety and Health
License and Certificate Unit
State Campus, Building 12
Albany, NY 12240

ASBESTOS HANDLING LICENSE

HSE Consulting Services, LLC

8636 Brewerton Road

Cicero, NY 13039

FILE NUMBER: 09-50181

LICENSE NUMBER: 50181

LICENSE CLASS: RESTRICTED

DATE OF ISSUE: 01/03/2019

EXPIRATION DATE: 01/31/2020

Duly Authorized Representative – Brian C King:

This license has been issued in accordance with applicable provisions of Article 30 of the Labor Law of New York State and of the New York State Codes, Rules and Regulations (12 NYCRR Part 56). It is subject to suspension or revocation for a (1) serious violation of state, federal or local laws with regard to the conduct of an asbestos project, or (2) demonstrated lack of responsibility in the conduct of any job involving asbestos or asbestos material.

This license is valid only for the contractor named above and this license or a photocopy must be prominently displayed at the asbestos project worksite. This license verifies that all persons employed by the licensee on an asbestos project in New York State have been issued an Asbestos Certificate, appropriate for the type of work they perform, by the New York State Department of Labor.



Eileen M. Franko, Director
For the Commissioner of Labor



Appendix 6

NYSDOL Asbestos Inspector Certification Documentation

ASBESTOS INSPECTOR CERTIFICATION DOCUMENTATION

PROJECT NAME

Asbestos Survey
Vacant Single-Family Residence
762 Schoharie Hill Road
Schoharie, New York 12157

CLIENT NAME

Greater Mohawk Valley Land Bank
500 E. Main Street, Suite 2A
Little Falls, New York 13365



SURVEY DATE

August 20, 2019

ASBESTOS INSPECTOR

Chad C. Gable
NYSDOL Certificate Number 12-10911
Expires 02/29/2020

Daniel R. Hoosock
NYSDOL Certificate Number 90-10890
Expires 02/29/2020





Appendix 7

Laboratory Analysis Reports & Chain-of-Custody Records



ASBESTOS ANALYSIS REPORT

Greater Mohawk Valley Land Bank
500 E. Main Street
Suite 2A
Little Falls NY 13365
Attention: John Mazzaella

Non-Gravimetrically Reduced Samples

Analysis Method - NY State ELAP 198.1/EPA 600/M4/82/020
NYS DOH ELAP ID #11973

Thursday, August 29, 2019
Batch Number: 10353
Date Received: 8/20/2019
Date Collected: 8/20/2019
Sampled By: Chad C. Gable

Project # Asbestos Survey
Project Name: 762 Schoharie Hill Rd., Schoharie, NY

Page 1 of 2

Lab ID	Sample ID	Color	Total % Asbestos	% AM	% CH	% CR	% TM	% AC	% AN	% CE	% MW	% GW	% SY	% HH	% O	Other Type	%Non- Fibrous Material	Date Analyzed
87036	CG82019-29	Light Gray	67		67					17							16	8/26/2019
87037	CG82019-30	White	2.6		2.6												97.4	8/26/2019
87038	CG82019-31	White	3.0		3.0												97	8/26/2019
87039	CG82019-32	White	2.2		2.2												97.8	8/26/2019
87040	CG82019-39	Beige	NAD							<1.0							100	8/26/2019
87041	CG82019-40	Beige	NAD							<1.0							100	8/26/2019
87042	CG82019-41	Beige	NAD							<1.0							100	8/26/2019
87043	CG82019-42	Off White/Brown	NAD							5							95	8/26/2019
87044	CG82019-43	Off White/Brown	NAD							5							95	8/26/2019
87045	CG82019-44	White	NAD														100	8/26/2019
87046	CG82019-45	White	NAD														100	8/26/2019

Abbreviations:

AM - Amosite
CH - Chrysotile
CR - Crocidolite

TM - Tremolite
AC - Actinolite
AN - Anthophyllite

CE - Cellulose
MW - Mineral Wool
GW - Glass Wool

SY - Synthetic
HH - Horse Hair
O - Other

TR - Trace asbestos detected at <1%
NAD- No Asbestos Detected
SAFP - Stop at First Positive (not analyzed)

N/A - Not Applicable
NA - Not Available
*Insufficient Sample for Analysis

The results pertain only to the samples in this report.

8636 Brewerton Road
Cicero, New York 13039

Ph # (315) 698-1438
Fax # (315) 698-1441
www.hseconsultingservices.com



ASBESTOS ANALYSIS REPORT

Greater Mohawk Valley Land Bank
500 E. Main Street
Suite 2A
Little Falls NY 13365
Attention: John Mazzaella

Non-Gravimetrically Reduced Samples

Analysis Method - NY State ELAP 198.1/EPA 600/M4/82/020
NYS DOH ELAP ID #11973

Thursday, August 29, 2019
Batch Number: 10353
Date Received: 8/20/2019
Date Collected: 8/20/2019
Sampled By: Chad C. Gable

Project # Asbestos Survey

Project Name: 762 Schoharie Hill Rd., Schoharie, NY

Page 2 of 2

Lab ID	Sample ID	Color	Total % Asbestos	% AM	% CH	% CR	% TM	% AC	% AN	% CE	% MW	% GW	% SY	% HH	% O	Other Type	%Non- Fibrous Material	Date Analyzed
87047	CG82019-46	Beige	NAD							100								8/26/2019
87048	CG82019-47	Beige	NAD							100								8/26/2019
87049	CG82019-50	Brown	NAD							95				5				8/26/2019
87050	CG82019-51	Brown	NAD							95				5				8/26/2019
87051	CG82019-54	Off White/Brown	NAD							5							95	8/26/2019
87052	CG82019-55	Off White/Brown	NAD							5							95	8/26/2019

Reviewed and Approved By (and for questions regarding this report):


Douglas L. Gee, Technical Director

Abbreviations:

AM - Amosite	TM - Tremolite	CE - Cellulose	SY - Synthetic	TR - Trace asbestos detected at <1%	N/A - Not Applicable
CH - Chrysotile	AC - Actinolite	MW - Mineral Wool	HH - Horse Hair	NAD- No Asbestos Detected	NA - Not Available
CR - Crocidolite	AN - Anthophyllite	GW - Glass Wool	O - Other	SAFP - Stop at First Positive (not analyzed)	*Insufficient Sample for Analysis

The results pertain only to the samples in this report.

8636 Brewerton Road
Cicero, New York 13039

Ph # (315) 698-1438
Fax # (315) 698-1441
www.hseconsultingservices.com



ASBESTOS ANALYSIS REPORT
Gravimetrically Reduced Samples
Non-Friable Organically Bound Material

Greater Mohawk Valley Land Bank
500 E. Main Street
Suite 2A
Little Falls NY 13365
Attention: John Mazzarella

PLM Analysis Method - NY State ELAP 198.6/EPA 600/M4/82/020
NYS DOH ELAP ID #11973
TEM Analysis Method - NY State ELAP 198.4
TEM Analysis Performed by NYSDOH ELAP ID #10920

Thursday, August 29, 2019
Batch Number: 10354
Date Received: 8/20/2019
Date Collected: 8/20/2019
Sampled By: Chad C. Gable

Project # Asbestos Survey

Project Name: 762 Schoharie Hill Rd., Schoharie, NY

Page 1 of 5

Lab ID	Sample ID	Color	% Residue	PLM ANALYSIS				TEM ANALYSIS				Total % Asbestos	Date Analyzed
				%	Type	%	Type	%	Type	%	Type		
87053	CG82019-1	Multi	10.2	NAD				NAD				NAD	8/22/2019
87054	CG82019-2	Multi	18.8	NAD				NAD				NAD	8/22/2019
87055	CG82019-3	Brown	22.6	NAD				NAD				NAD	8/22/2019
87056	CG82019-4	Brown	21.2	NAD				NAD				NAD	8/22/2019
87057	CG82019-5	Black	38.8	26	CH			N/A				26	8/22/2019
87058	CG82019-6	Black	38.0	25	CH			N/A				25	8/22/2019
87059	CG82019-7	Brown	42.9	NAD				NAD				NAD	8/22/2019
87060	CG82019-8	Brown	42.2	NAD				NAD				NAD	8/22/2019
87061	CG82019-9	Black	4.6	NAD				NAD				NAD	8/22/2019
87062	CG82019-10	Black	5.9	NAD				NAD				NAD	8/22/2019
87063	CG82019-11-1	Black	7.1	NAD				NAD				NAD	8/22/2019

Abbreviations:

AM - Amosite N/A - Not Applicable
CH - Chrysotile NA - Not Available
CR - Crocidolite NAD - No Asbestos Detected
TM - Tremolite SAFFP - Stop at First Positive
AC - Actinolite (not analyzed)
AN - Anthophyllite NR - Not Required
<1.0% Residue Remaining

TR - Trace asbestos detected at less than 1%.

*Insufficient sample for analysis (**Samples not analyzed must not be interpreted as being non-ACM**)

** - Inconclusive, No Asbestos Detected (**Samples with inconclusive results must not be interpreted as being non-ACM**)

***TEM analysis not performed per client's request. (Polarized-light microscopy is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-ACM.

NOTE: The results pertain only to the samples in this report.

8636 Brewerton Road
Cicero, New York 13039

Ph # (315) 698-1438
Fax # (315) 698-1441
www.hseconsultingservices.com



ASBESTOS ANALYSIS REPORT
Gravimetrically Reduced Samples
Non-Friable Organically Bound Material

Greater Mohawk Valley Land Bank
500 E. Main Street
Suite 2A
Little Falls NY 13365
Attention: John Mazzarella

PLM Analysis Method - NY State ELAP 198.6/EPA 600/M4/82/020
NYS DOH ELAP ID #11973
TEM Analysis Method - NY State ELAP 198.4
TEM Analysis Performed by NYSDOH ELAP ID #10920

Thursday, August 29, 2019
Batch Number: 10354
Date Received: 8/20/2019
Date Collected: 8/20/2019
Sampled By: Chad C. Gable

Project # Asbestos Survey

Project Name: 762 Schoharie Hill Rd., Schoharie, NY

Page 2 of 5

Lab ID	Sample ID	Color	% Residue	PLM ANALYSIS				TEM ANALYSIS				Total % Asbestos	Date Analyzed
				%	Type	%	Type	%	Type	%	Type		
87064	CG82019-11-2	Brown	20.4	NAD				NAD				NAD	8/22/2019
87065	CG82019-12-1	Black	1.4	NAD				NAD				NAD	8/22/2019
87066	CG82019-12-2	Brown	29.9	NAD				TR	CH			TR	8/22/2019
87067	CG82019-13-1	Brown/Beige	35.4	NAD				NAD				NAD	8/22/2019
87068	CG82019-13-2	Brown/Beige	44.8	NAD				NAD				NAD	8/22/2019
87069	CG82019-14-1	Brown/Beige	34.8	NAD				NAD				NAD	8/22/2019
87070	CG82019-14-2	Brown/Beige	40.9	NAD				NAD				NAD	8/22/2019
87071	CG82019-17	Off White	2.8	NAD				NAD				NAD	8/22/2019
87072	CG82019-18	Off White	3.9	NAD				NAD				NAD	8/22/2019
87073	CG82019-19-1	Brown/Tan	11.4	NAD				NAD				NAD	8/22/2019
87074	CG82019-19-2	Black	2.0	NAD				NAD				NAD	8/22/2019

Abbreviations:

AM - Amosite N/A - Not Applicable
CH - Chrysotile NA - Not Available
CR - Crocidolite NAD - No Asbestos Detected
TM - Tremolite SAFFP - Stop at First Positive
AC - Actinolite (not analyzed)
AN - Anthophyllite NR - Not Required
<1.0% Residue Remaining

TR - Trace asbestos detected at less than 1%.

*Insufficient sample for analysis (**Samples not analyzed must not be interpreted as being non-ACM**)

** - Inconclusive, No Asbestos Detected (**Samples with inconclusive results must not be interpreted as being non-ACM**)

***TEM analysis not performed per client's request. (Polarized-light microscopy is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-ACM.

NOTE: The results pertain only to the samples in this report.

8636 Brewerton Road
Cicero, New York 13039

Ph # (315) 698-1438
Fax # (315) 698-1441
www.hseconsultingservices.com



ASBESTOS ANALYSIS REPORT Gravimetrically Reduced Samples Non-Friable Organically Bound Material

Greater Mohawk Valley Land Bank
500 E. Main Street
Suite 2A
Little Falls NY 13365
Attention: John Mazzarella

PLM Analysis Method - NY State ELAP 198.6/EPA 600/M4/82/020
NYS DOH ELAP ID #11973
TEM Analysis Method - NY State ELAP 198.4
TEM Analysis Performed by NYSDOH ELAP ID #10920

Thursday, August 29, 2019
Batch Number: 10354
Date Received: 8/20/2019
Date Collected: 8/20/2019
Sampled By: Chad C. Gable

Project # Asbestos Survey

Project Name: 762 Schoharie Hill Rd., Schoharie, NY

Page 3 of 5

Lab ID	Sample ID	Color	% Residue	PLM ANALYSIS				TEM ANALYSIS				Total % Asbestos	Date Analyzed
				%	Type	%	Type	%	Type	%	Type		
87075	CG82019-20-1	Brown/Tan	12.1	NAD				NAD				NAD	8/22/2019
87076	CG82019-20-2	Black	3.1	NAD				TR	CH			TR	8/22/2019
87077	CG82019-21	Beige	40.0	NAD				NAD				NAD	8/22/2019
87078	CG82019-22	Beige	40.3	NAD				NAD				NAD	8/22/2019
87079	CG82019-23	Dark Brown	49.0	NAD				TR	CH			TR	8/22/2019
87080	CG82019-24	Dark Brown	48.9	NAD				NAD				NAD	8/22/2019
87081	CG82019-25	Multi	15.7	NAD				NAD				NAD	8/22/2019
87082	CG82019-26	Multi	13.5	NAD				NAD				NAD	8/22/2019
87083	CG82019-27	Off White	2.1	NAD				NAD				NAD	8/22/2019
87084	CG82019-28	Off White	10.4	NAD				NAD				NAD	8/22/2019
87085	CG82019-33	Brown	10.0	NAD				TR	CH			TR	8/22/2019

Abbreviations:

AM - Amosite N/A - Not Applicable
CH - Chrysotile NA - Not Available
CR - Crocidolite NAD - No Asbestos Detected
TM - Tremolite SAFF - Stop at First Positive
AC - Actinolite (not analyzed)
AN - Anthophyllite NR - Not Required
<1.0% Residue Remaining

TR - Trace asbestos detected at less than 1%.

*Insufficient sample for analysis (**Samples not analyzed must not be interpreted as being non-ACM**)

** - Inconclusive, No Asbestos Detected (**Samples with inconclusive results must not be interpreted as being non-ACM**)

***TEM analysis not performed per client's request. (Polarized-light microscopy is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-ACM.

NOTE: The results pertain only to the samples in this report.

8636 Brewerton Road
Cicero, New York 13039

Ph # (315) 698-1438
Fax # (315) 698-1441
www.hseconsultingservices.com



ASBESTOS ANALYSIS REPORT Gravimetrically Reduced Samples Non-Friable Organically Bound Material

Greater Mohawk Valley Land Bank
500 E. Main Street
Suite 2A
Little Falls NY 13365
Attention: John Mazzaarella

PLM Analysis Method - NY State ELAP 198.6/EPA 600/M4/82/020
NYS DOH ELAP ID #11973
TEM Analysis Method - NY State ELAP 198.4
TEM Analysis Performed by NYSDOH ELAP ID #10920

Thursday, August 29, 2019
Batch Number: 10354
Date Received: 8/20/2019
Date Collected: 8/20/2019
Sampled By: Chad C. Gable

Project # Asbestos Survey

Project Name: 762 Schoharie Hill Rd., Schoharie, NY

Page 4 of 5

Lab ID	Sample ID	Color	% Residue	PLM ANALYSIS				TEM ANALYSIS				Total % Asbestos	Date Analyzed
				%	Type	%	Type	%	Type	%	Type		
87086	CG82019-34	Brown	6.1	NAD				TR	CH			TR	8/22/2019
87087	CG82019-35	Black	8.9	NAD				NAD				NAD	8/22/2019
87088	CG82019-36	Black	1.6	NAD				NAD				NAD	8/22/2019
87089	CG82019-37	Gray	12.6	5.6	CH			N/A				5.6	8/22/2019
87090	CG82019-38	Gray	13.8	6.9	CH			N/A				6.9	8/22/2019
87091	CG82019-48	Black/Beige	7.7	NAD				NAD				NAD	8/22/2019
87092	CG82019-49	Black/Beige	1.4	NAD				NAD				NAD	8/22/2019
87093	CG82019-52	Black/Gray	40.4	NAD				TR	CH			TR	8/22/2019
87094	CG82019-53	Black/Gray	24.0	NAD				NAD				NAD	8/22/2019
87095	CG82019-56	Gray/Black	49.8	NAD				TR	TM			TR	8/22/2019
87096	CG82019-57	Gray/Black	55.1	NAD				NAD				NAD	8/22/2019

Abbreviations:

AM - Amosite N/A - Not Applicable
CH - Chrysotile NA - Not Available
CR - Crocidolite NAD - No Asbestos Detected
TM - Tremolite SAFFP - Stop at First Positive
AC - Actinolite (not analyzed)
AN - Anthophyllite NR - Not Required
<1.0% Residue Remaining

TR - Trace asbestos detected at less than 1%.

*Insufficient sample for analysis (**Samples not analyzed must not be interpreted as being non-ACM**)

** - Inconclusive, No Asbestos Detected (**Samples with inconclusive results must not be interpreted as being non-ACM**)

***TEM analysis not performed per client's request. (Polarized-light microscopy is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-ACM.

NOTE: The results pertain only to the samples in this report.

8636 Brewerton Road
Cicero, New York 13039

Ph # (315) 698-1438
Fax # (315) 698-1441
www.hseconsultingservices.com



ASBESTOS ANALYSIS REPORT Gravimetrically Reduced Samples Non-Friable Organically Bound Material

Greater Mohawk Valley Land Bank
500 E. Main Street
Suite 2A
Little Falls NY 13365
Attention: John Mazzarella

PLM Analysis Method - NY State ELAP 198.6/EPA 600/M4/82/020
NYS DOH ELAP ID #11973
TEM Analysis Method - NY State ELAP 198.4
TEM Analysis Performed by NYSDOH ELAP ID #10920

Thursday, August 29, 2019
Batch Number: 10354
Date Received: 8/20/2019
Date Collected: 8/20/2019
Sampled By: Chad C. Gable


Project # Asbestos Survey

Project Name: 762 Schoharie Hill Rd., Schoharie, NY

Page 5 of 5

Lab ID	Sample ID	Color	PLM ANALYSIS			TEM ANALYSIS			Total % Asbestos	Date Analyzed
			% Residue	%	Type	%	Type	%		
87097	CG82019-58	Black/Brown	23.6	NAD				NAD	NAD	8/22/2019
87098	CG82019-59	Black/Brown	25.0	NAD				NAD	NAD	8/22/2019

Reviewed and Approved By (and for questions regarding this report):


Douglas L. Gee, Technical Director

Abbreviations:

AM - Amosite N/A - Not Applicable
CH - Chrysotile NA - Not Available
CR - Crocidolite NAD - No Asbestos Detected
TM - Tremolite SAFF - Stop at First Positive
AC - Actinolite (not analyzed)
AN - Anthophyllite NR - Not Required
<1.0% Residue Remaining

TR - Trace asbestos detected at less than 1%.

*Insufficient sample for analysis (**Samples not analyzed must not be interpreted as being non-ACM**)

** - Inconclusive, No Asbestos Detected (**Samples with inconclusive results must not be interpreted as being non-ACM**)

***TEM analysis not performed per client's request. (Polarized-light microscopy is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-ACM.

NOTE: The results pertain only to the samples in this report.

8636 Brewerton Road
Cicero, New York 13039

Ph # (315) 698-1438
Fax # (315) 698-1441
www.hseconsultingservices.com



ASBESTOS ANALYSIS REPORT

Gravimetrically Reduced Samples

Friable Material

Greater Mohawk Valley Land Bank
500 E. Main Street
Suite 2A
Little Falls NY 13365
Attention: John Mazzaella

PLM Analysis Method - NY State ELAP 198.6/EPA 600/M4/82/020
NYS DOH ELAP ID #11973

TEM Analysis Method - NY State ELAP 198.4
TEM Analysis Performed by NYSDOH ELAP ID #10920

Thursday, August 29, 2019

Batch Number: 10355
Date Received: 8/20/2019
Date Collected: 8/20/2019
Sampled By: Chad C. Gable

Project # Asbestos Survey

Project Name: 762 Schoharie Hill Rd., Schoharie, NY

Page 1 of 1

Lab ID	Sample ID	Color	% Residue	PLM ANALYSIS				TEM ANALYSIS				Total % Asbestos	Date Analyzed
				%	Type	%	Type	%	Type	%	Type		
87099	CG82019-15	White/Tan	14.9	NAD					NAD			NAD	8/22/2019
87100	CG82019-16	White/Tan	14.7	NAD					NAD			NAD	8/22/2019

Reviewed and Approved By (and for questions regarding this report): Douglas L. Gee
Douglas L. Gee, Technical Director

Abbreviations:

AM - Amosite N/A - Not Applicable
CH - Chrysotile NA - Not Available
CR - Crocidolite NAD - No Asbestos Detected
TM - Tremolite SAFF - Stop at First Positive
AC - Actinolite (not analyzed)
AN - Anthophyllite NR-Not Required

TR - Trace asbestos detected at less than 1%
*Insufficient sample for analysis (Samples not analyzed must not be interpreted as being non-ACM)
** - Inconclusive, No Asbestos Detected (Samples with inconclusive results must not be interpreted as being non-ACM)
***TEM analysis not performed per client's request. (Polarized-light microscopy is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. Quantitative transmission electron microscopy is currently the only method that can be used to determine if this material can be considered or treated as non-ACM.

NOTE: The results pertain only to the samples in this report.

8636 Brewerton Road
Cicero, New York 13039

Ph # (315) 698-1438
Fax # (315) 698-1441
www.hseconsultingservices.com



8636 Brewerton Road, Cicero, NY 13039
Phone: 315-698-1438 / Fax: 315-698-1441

Date: 8-20-2019

Bulk/Surface Sample Log

Page 1 of 3

For Lab Use Only

10353 - 87036 - 87052 (198.1)
Batch # 10354 - 87053 - 87098 (198.2)
10355 - 87099 - 87100 (198.6F)

Project Name: Asbestos Survey	Client Name: Greater Mohawk Valley LB	Contact: John Mazzarella
Project Address: 762 Schoharie Hill Rd., Schoharie, NY	Address: 500 E. Main Street, Suite 2A	Phone/Fax: 315-823-0814
	Little Falls, New York 13365	E-mail: johnm@gmvlb.org

For Lab Use Only			
Sample No.	Sample Location	Sample Description	Type
CG82019-1	101	Flower Pattern Linoleum	
CG82019-2	101	↓	
CG82019-3	101	Square Pattern Linoleum	
CG82019-4	101	↓	
CG82019-5	102	Sink ceiling	
CG82019-6	102	Sink ceiling	
CG82019-7	102	wall paneling waste	
CG82019-8	102	↓	
CG82019-9	102	Block 9x9	
CG82019-10	102	↓	
CG82019-11	102	Black backing to black 9x9 mosaic	
CG82019-12	102	↓	
CG82019-13	102	Brown 9x9 w/ waste	
CG82019-14	102	↓	
CG82019-15	104	1x1 ceiling tile	
CG82019-16	104	↓	
CG82019-17	104	Tub caulking	
CG82019-18	104	↓	
CG82019-19	104	multi color floor tile black	
CG82019-20	104	backing	

Sample Types: ASBESTOS: F=Friable NF=Non-Friable NOB=Non-Friable Organically Bound	SAFP? Y/N
MOLD: T=Tape Lift S=Swab	

Chain of Custody	Signature	Date	Time
Sampled by:	Chad C. Gable	8/20/2019	1015
Relinquished by:	Chad C. Gable	8/20/2019	1537
Received at Lab by:	Michael Norman	8/20/2019	1545
Turnaround Time:	☐ RUSH (Specify): ☐ 12 Hour ☐ 24 Hour ☐ 48 Hour ☐ 72 Hour ☒ Standard (5 Day)		



8636 Brewerton Road, Cicero, NY 13039
Phone: 315-698-1438 / Fax: 315-698-1441

Date: 8-20-2019

Bulk/Surface Sample Log

Page 2 of 3

For Lab Use Only

Batch # 10353 - 87052 (198.1)
10354 - 87053 - 87055 (198.6)
10355 - 87056 - 87057 (198.6 F)

Project Name: Asbestos Survey	Client Name: Greater Mohawk Valley LB	Contact: John Mazzarella
Project Address: 762 Schoharie Hill Rd., Schoharie, NY	Address: 500 E. Main Street, Suite 2A	Phone/Fax: 315-823-0814
	Little Falls, New York 13365	E-mail: johnm@gmvlb.org

For Lab Use Only			
Sample No.	Sample Location	Sample Description	Type
CG82019-21	104	9x9 beige/black VCT	
CG82019-22	104	↓	
CG82019-23	104	mastic to beige black 9x9	
CG82019-24	104	↓	
CG82019-25	104 closet	multi color pattern linoleum	
CG82019-26	104 closet	↓	
CG82019-27	104	ceramic wall tile mastic	
CG82019-28	104	↓	
CG82019-29	B1	duct seam tape	
CG82019-30	103	ceiling texture	
CG82019-31	103	↓	
CG82019-32	103		
CG82019-33	103	9x9 wood grain vct	
CG82019-34	103	↓	
CG82019-35	103	black backing to 9x9 wood	
CG82019-36	103	↓	
CG82019-37	103	wood paneling mastic	
CG82019-38	103	↓	
CG82019-39	201	plaster	
CG82019-40	203 205	plaster	

Sample Types: ASBESTOS: F=Friable NF=Non-Friable NOB=Non-Friable Organically Bound	SAF? Y/N	
MOLD: T=Tape Lift S=Swab		
Chain of Custody	Signature	Date
Sampled by:	Chad C. Gable	8/20/2019
Relinquished by:	Chad C. Gable	8/20/2019
Received at Lab by:	Michael Norman	8/20/2019
Turnaround Time:	☐ RUSH (Specify): ☐ 12 Hour ☐ 24 Hour ☐ 48 Hour ☐ 72 Hour ☒ Standard (5 Day)	Time



8636 Brewerton Road, Cicero, NY 13039
Phone: 315-698-1438 / Fax: 315-698-1441

Date: 8-20-2019

Bulk/Surface Sample Log

Page 3 of 3

For Lab Use Only

10555 - 87056 - 87052 (198.1)
Batch # 10554 - 87053 - 87048 (198.6)
10555 - 87049 - 87100 (198.6F)

Project Name: Asbestos Survey	Client Name: Greater Mohawk Valley LB	Contact: John Mazzarella
Project Address: 762 Schoharie Hill Rd., Schoharie, NY	Address: 500 E. Main Street, Suite 2A	Phone/Fax: 315-823-0814
	Little Falls, New York 13365	E-mail: johnm@gmvb.org

For Lab Use Only						
Sample No.	Sample Location	Sample Description	Type	Layers	Analysis Method	Lab ID
CG82019-41	204	Plaster			198.1	87042
CG82019-42	203 202	Drywall				87043
CG82019-43	203	↓				87044
CG82019-44	202	Joint compound				87045
CG82019-45	203	↓				87046
CG82019-46	202	Joint tape				87047
CG82019-47	203	↓				87048
CG82019-48	ext 5	Window glazing compound			198.6	87049
CG82019-49		↓ ext 5.			↓	87092
CG82019-50	207	Brown paper			198.1	87049
CG82019-51	207	↓			↓	87050
CG82019-52	open porch 2nd floor	white rolled roofing			198.6	87093
CG82019-53	↓	↓			↓	87094
CG82019-54	202 102	drywall			198.1	87051
CG82019-55	104	↓			↓	87052
CG82019-56	Main Roof South	Gray Shingle			198.6	87095
CG82019-57	↓	↓			↓	87096
CG82019-58		Tar Paper				87097
CG82019-59	↓	↓			↓	87098
CG82019-60						

Sample Types: ASBESTOS: F=Friable NF=Non-Friable NOB=Non-Friable Organically Bound	SAFP? Y/N	
MOLD: T=Tape Lift S=Swab		
Chain of Custody	Signature	Date
Sampled by: Chad C. Gable	<i>Chad C. Gable</i>	8/20/2019
Relinquished by: Chad C. Gable	<i>Chad C. Gable</i>	8/20/2019
Received at Lab by: Michael Norman	<i>Michael Norman</i>	8/20/2019
Turnaround Time: ☐ RUSH (Specify): ☐ 12 Hour ☐ 24 Hour ☐ 48 Hour ☐ 72 Hour ☒ Standard (5 Day)		Time
		1545



Appendix 8

NYSDOH ELAP Certificates of Approval

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2020
Issued April 01, 2019

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MR. BRIAN C. KING
HSE CONSULTING SERVICES, LLC
8636 BREWERTON ROAD
CICERO, NY 13039

NY Lab Id No: 11973

*is hereby APPROVED as an Environmental Laboratory for the category
ENVIRONMENTAL ANALYSES SOLID AND HAZARDOUS WASTE
All approved subcategories and/or analytes are listed below:*

Miscellaneous

Asbestos in Friable Material

Item 198.1 of Manual

EPA 600/M4/82/020

Asbestos in Non-Friable Material-PLM

Item 198.6 of Manual (NOB by PLM)



Department
of Health

Serial No.: 59927

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.